

Forward to AXA Power Fax + 45 63 18 60 49 Phone + 45 63 18 60 00 Mail : service@axapower.com	Sender	AXA2300 GPU information
	Company :	Type :
	Fax :	Serial No. :
	Phone :	Error Code : / /
	Contact :	Please always state serial no. of the faulty GPU
E-mail :		

How to retrieve parameters from the Alarm Log :

1. Press one of the arrows  until you reach the **Alarm Log**.

2. Press arrow **up**  to enter Alarm Log.

3. Press **center** button  to enter detailed parameters.

4. Press arrows **up**  and read out the following information :

Input voltage	L1-L2 : V	L2-L3 : V	L3-L1 : V
Input frequency	Hz		
Voltage at DC capacitor bank	DC 1 : V	DC 2 : V	SUM : V
Output voltage phase-neutral	A-N : V	B-N : V	C-N : V
Inverter current	Ph A : A	Ph B : A	Ph C : A
Output current	Ph A : A	Ph B : A	Ph C : A
Module temp.	Front : C°	Rear : C°	
Internal DC volt.	-5V : V	12 V : V	17 V : V
			24 V : V
Setup values	Voltage : V	Cable Compensation : V	

Other indication (lamps, LED's, damages of enclosure etc.) :

Remarks :

Spare parts are available at www.axapower.com